
Electrical Distribution Safety

DISTRIBUTION COMPANY AWARENESS:

Utilities replacing existing delta supply transformers with grounded wye or star supply transformers must be aware of the requirements under the Ontario Electrical Safety Code (OESC) in relation to customer services.

This bulletin is to inform LDC's the previous OESC Bulletin 4-9-2 "Requirements for Delta to Wye conversions" has been superseded and replaced with **Bulletin 10-22-0 "Requirements for converting a delta service to a grounded wye service"**.

http://www.esasafe.com/pdf/Sample_Bulletins/2009-ESA-Binder-10-22-0.pdf

Work up to the demarcation point falls under the requirements of Ontario Regulation 22/04. Work past the demarcation point shall include the 4th or neutral wire, and meet the requirements of the OESC and Contractor Licensing. This will include filing an application for inspection with ESA.



ADDITIONAL INFORMATION:

Information requests and follow-up may be directed to ESA at Utility.Regulations@ElectricalSafety.on.ca. For questions on this bulletin please be prepared to quote Bulletin "DSB-04/11".